

GLASS BLOCK QUESTIONS:

GL1: (Q21:) What is the size of Specimen required to test glass blocks?

A: The specimen shall be 4' x 8' and built as specified in the South Florida Building Code.

GL2: (Q22:) -Reserved.

GL3: (Q23:) Where do glass block specimens have to be impacted?

A: At the center of the block nearest to the center of the specimen, and 6" away from a corner.

GL4: (Q76:) Question 21 for glass blocks specifies that you must test 4' x 8' samples; can you use 4' x 4' samples instead?

A: Yes.

GL5: (Q77:) Reserved.

GL6: (Q104:) In question 22, all sizes of glass blocks had to be tested. Is that still the case?

A: No. Dade County has allowed testing the largest glass block your company wishes to receive product approval for and smaller dimension glass blocks will be accepted for approval.